



Ship Unloader Crane Removal

Specification Booklet

Project Name Ship Unloader Crane Removal

Project No. 11781 **Task No.** 01 **Addendum No.** 3

To: Prospective Bidders **Date:** 5/22/2026

The following are answers to questions received.

Item	Description
Questions	
1.	Can the Port provide hydrographic surveys to the east (front) and west (back) of Dock 1 "S" Crane? <i>Answer: Hydrographic surveys cannot be provided at this time. However, the channel and berth on the east side of Dock 1 is maintained to 50 feet. The west side of Dock 1 is roughly 8 – 12 feet deep.</i>

Please indicate your receipt of this addendum by adding the addendum number in the appropriate place in your Specification Book.

Project Manager:

5/22/2026

Kyle Strachan, P.E.